

ELECTROCENTRALE BUCUREȘTI S.A.

„in reorganizare judiciară”, „in judicial reorganisation”, „en redressement”

Splaiul Independenței nr. 227, cod poștal 060041, sector 6, București

Tel.: +4021.275.11.03, Fax: +4021.275.14.05

office@elcen.ro, www.elcen.ro

C.U.I.: 15189596, R.C.: 140/1696/2003

ELCEN**Anexa nr. 3****FISA TEHNICA****Kit piese uzura pentru pompa de dozare cu piston****2 buc****Date pompa:****Fabricant:****Sera****Model:****RF 409.2-12K.****Fluid de lucru:****fosfat trisodic (Na_3PO_4)****PUMP DATA**

Permissible pressure p2max at the pump outlet	bar		140	140	80
Nominal capacity QN at p2 max.	l/h	50 Hz	8	12	18
	l/h	60 Hz	10	14	22
	ml/stroke		1,3	1,3	3,0
Max suction height	mWC		3	3	3
Min./max. permissible pressure at the pump inlet	bar		-0,3/0	-0,3/0	-0,3/0
Recommended nominal diameter DN of the connecting pipes			8	8	8
Nominal stroke frequency	l/h	50 Hz	100	150	100
	l/min	60 Hz	120	180	120
Weight approx	kg		12	12	12

ELECTRICAL CONNECTION DATA

Power consumption	W		0,37	0,37	0,37
Voltage	V	50 Hz	230/400	230/400	230/400
	V	60 Hz	/460	/460	/460
Frequency	Hz		50/60	50/60	50/60
Protection category	IP		55	55	55

Director CTE VEST

Dan TUDOR

Sef sectie Ciclu Combinat,
Costin ZISU